




PT DSSP POWER SUMSEL		Scope of Work		PR No. 400005638
Plant	DSSP Power Sumsel	Department	Electrical Maintenance	
Equipment Name	Crane	Equipment KKS Code		
Area	BTG	Unit	Unit 2	
Project Title Description	Crane Repair Unit#2 Batch 1 after inspection			
<input type="checkbox"/> New <input type="checkbox"/> Modification <input checked="" type="checkbox"/> Replace <input checked="" type="checkbox"/> Repair <input type="checkbox"/> Service PM				
No	Specific Scope of Works	Quantity	Remarks	
1	Hoist Crane Boiler Secondary Air Fan 2B 10 Ton SN: 1400687 Capacity: 10 t Single girder EOT - 1 trolley wire rope hoist, Secondary Air Fan 2B		Local contractor will work under Electrical and CDTO supervision to carry out following activities: 1. Repair Trolley idle wheel and bearings 2. Repair Powerail Busbar KBSL 4/140 and supply material Set include accessories -Busbar KBSL 4/140 HS ( 3 EA ) -Sliding hanger ( 9 EA ) -Fixpoin hanger busbar ( 3 EA ) -Current collector ( 1 Ea ) -End feed busbar KBSL ( 1 EA ) include repair dan replace	
2	Hoist Crane Boiler IDF 2 AB 10 Ton SN: 1400215 Capacity: 10 t Single girder EOT - 1 trolley wire rope hoist, IDF 2 AB	1 lot	Local contractor will work under Electrical and CDTO supervision to carry out following activities: 1. Repair Powerail Busbar KBSL 4/140 and supply material set include accessories, such as -Busbar KBSL 4/140 HS ( 8 EA ) -Sliding hanger ( 24 EA ) -Fixpoin hanger busbar ( 5 EA ) -Current collector ( 1 Ea ) -End feed busbar KBSL ( 1 EA ) include repair dan replace	
3	Hoist Crane Turbine House Double Girder Rope Hoist 75/20ton SN: 0781 Capacity: 75 t Double girder EOT 2 trolleys wire rope hoists, Turbine House		Local contractor will work under Electrical and CDTO supervision to carry out following activities: 1. Repair Powerail Busbar and supply material: -Power conductor KYEC 4 Pole for curva ( 3 Meter ) -Fix bracket ( 50 EA ) -Hanger clamp ( 50 EA ) -Line feed ( 1 EA ) -End tensioner ( 2 EA ) -Current collector ( 1 Ea ) include repair dan replace	

Note:

- The vendor's workers must hold a valid Working at Height Certificate (TKPK/Tenaga Kerja Pada Ketinggian) issued by the Department of Manpower (Dinas Ketenagakerjaan) or the Minister of Manpower.
- The vendor must provide complete Personal Protective Equipment (PPE) for all workers.
- Workers must have a minimum of three (3) years of experience in hoist crane operations.
- The scope shall include meals, worker mobilization and demobilization, as well as mobilization and demobilization of materials and accessories.
- Conducting a site visit will be an added advantage to obtain clearer information and avoid any misunderstanding of the job scope.

No	Work Description	Common Scope of Work	Remarks	
1	General Scope	Cleaning working area after finish	<input checked="" type="checkbox"/>	
		Operational training for new equipment	<input checked="" type="checkbox"/>	
		Warranty of Product/Work	<input checked="" type="checkbox"/>	
		General Lighting	<input checked="" type="checkbox"/>	
		Portable Lighting	<input checked="" type="checkbox"/>	
		Overall security	<input checked="" type="checkbox"/>	
2	Temporary Facility Scope	Accommodation / Dormitory	<input checked="" type="checkbox"/>	
		Mob and de-mob manpower	<input checked="" type="checkbox"/>	
		Mob and de-mob tool and equipment	<input checked="" type="checkbox"/>	
		Local transportation for manpower, material, equipment	<input checked="" type="checkbox"/>	
		Meal & Drinking	<input checked="" type="checkbox"/>	
		Site offices & rest shelter	<input checked="" type="checkbox"/>	
		Scaffold installation and dismantle	<input checked="" type="checkbox"/>	
		Secure site - Safety Inspector facilities	<input checked="" type="checkbox"/>	
3	HSE Concern Scope	First aid & Medical for worker	<input checked="" type="checkbox"/>	
		Fire fighting equipment (Extinguisher)	<input checked="" type="checkbox"/>	
		General Safety PPE (Safety Shoes, Helmet, Uniform, Scythlight, Mask)	<input checked="" type="checkbox"/>	
		Specific Safety PPE & Tools	<input checked="" type="checkbox"/>	
		Safety Officer (minimum AK3 Umum)	<input checked="" type="checkbox"/>	
		Certification manpower (GTAW, SMAW, Scaffolder, High working)	<input checked="" type="checkbox"/>	
		Follow Contractor Safety Management System (CSMS) procedure	<input checked="" type="checkbox"/>	
4	Consumables & Tool Scope	Consumable (wag cotton, insulation tape, etc.)	<input checked="" type="checkbox"/>	
		Crane/winch or other lifting equipment	<input checked="" type="checkbox"/>	
		Compressed air sources	<input checked="" type="checkbox"/>	
		Water resources	<input checked="" type="checkbox"/>	
		Electrical resources	<input checked="" type="checkbox"/>	
		Special work tools (inspected)	<input checked="" type="checkbox"/>	
5	Health, Safety, Environment & Energy Policy	Follow DSSP Internal Memo Kebijakan ke Vendor Setelah Pandemi	<input checked="" type="checkbox"/>	
		Follow DSSP Procedure of B3 Waste and Domestic Waste Disposal	<input checked="" type="checkbox"/>	
		Follow DSSP Energy Policy and Management System Requirement	<input checked="" type="checkbox"/>	
REMARKS		<input checked="" type="checkbox"/> Vendor Scope	<input checked="" type="checkbox"/> Not Vendor Scope	
	Position	Name	Signature	Date
Proposed By	Electrical Planner	Dinda Sintia		19/11/25
Reviewed By	Dy / Head Electrical	Inghon S		19.11.2025
	Maintenance Division Head	Chandra D		

1. Hoist Crane Boiler Secondary Air Fan 2B 10 Ton

SN: 1400687

Capacity: 10 t

Single girder EOT -

1 trolley wire rope hoist, Secondary Air Fan 2B

Hoist Crane Boiler Secondary Air Fan 2B 10 Ton, Conductor, Other fault



Hoist Crane Boiler Secondary Air Fan 2B 10 Ton, Conductor, Other fault



v 11 69 in

2. Hoist Crane Boiler IDF 2 AB 10 Ton

SN: 1400215

Capacity: 10 t

Single girder EOT - 1 trolley wire rope hoist, IDF 2 AB

Hoist Crane Boiler IDF 2 AB 10 Ton, Power supply, Other fault



Hoist Crane Boiler IDF 2 AB 10 Ton, Power supply, Other fault



3. Hoist Crane Turbine House

Double Girder Rope Hoist 75/20ton

SN: 0781

Capacity: 75 t

Double girder EOT

2 trolleys wire rope hoists, Turbine House

